

# FTI-10A

Designed for 1-4 Tanks of 30,000 gallons or less of stored diesel fuel.

FM Approved and NFPA compliant diesel fuel maintenance equipment

NEMA 3R compliant 2-door cabinet with zinc primer and powder coat finish.

48.0" W x 48.0" H x 16.5" D

## Features:

Primer Tee

Sight Glass

UL Listed Controller

99% fuel sediment removal (1 Micron)

Nearly 100% water removal

Modbus RTU Communications

**Used in:**  
Hospitals  
Data Centers  
Prisons  
Hotels

Automatic fuel filtration runs on an optimum schedule with auto shut-off & alarms for:

Water detection

Filter saturation

Leak detection

Flow loss

High pressure

Motor overload



Optional: Multi-tank Submersible pump

Optional: Fuel Transfer

Optional: Control panel strip heater



**Flotronix**

Flotronix Corporation  
12574 Promise Creek LN, Suite 118  
Fishers, IN 46038-77136

317-849-7377