

# FTI-2.8A

Designed for a single tank of 5,000 gallons or less of stored diesel fuel.

FM Approved and NFPA compliant diesel fuel maintenance equipment

NEMA 3R compliant single door cabinet with zinc primer and powder coat finish.

24.0" W x 24.0" H x 9.0" D

## Features:

- UL Listed Controller
- 99% fuel sediment removal (2 Micron)
- Nearly 100% water removal

**Used in:**  
Med Clinics  
Banks  
Government  
Facilities

Automatic fuel filtration runs on an optimum schedule with auto shut-off & alarms for:

- Water detection
- Filter saturation
- Leak detection
- Motor overload



Optional: Modbus RTU Communications  
Optional: Control panel strip heater



**Flotronix**

Flotronix Corporation  
12574 Promise Creek LN, Suite 118  
Fishers, IN 46038-77136

317-849-7377